

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1180838

**Product:** Switchgear and controlgear assembly

**Type:** BR-SL (see Annex)

**Rating:** 230 V, 50 Hz, max. 32 A, lcw 10 kA, IP55/00, IP55/00

**Ordering firm:** BREMA, spol. s r.o.  
Klánova 1535/65a, 147 00 Praha 4, Czech Republic

**Manufacturer:** BREMA, spol. s r.o.  
Klánova 1535/65a, 147 00 Praha 4, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 803605-01/01 of: 13.12.2018

**A sample of the product was found to be in conformity with:**

ČSN EN 61439-2 ed. 2:12, ČSN EN 61439-1 ed. 2:12+1:15

cl. 5, 6, 10.2.1, 10.2.7, 10.3, 10.4, 10.5.2, 10.6, 10.6.2, 10.7, 10.8, 10.9.2, 10.9.3, 10.10.4, 10.11.2, 10.12 (J.9.4.3.1, J.9.4.4.1), 10.13

**Other data:**

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 803605 between the client and the Electrotechnical Testing Institute.

**Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 117/2016 Sb. (2014/30/EU), 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.**

**The validity of the certificate is limited to:** 31.12.2021

17.12.2018

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



803605-01

	manufacturer	type of switchgear assembly	rated current (A)	short circuit endurance (kA)	enclosure IP	quantity of sections	measurement (mm)	number of inputs	number of outputs F	number of outputs K	special equipments
testing sample	BR	SL	10	10	55/00	1	800x2100x500	1	1F	160K	
max			32	10	55/00						*



*[Handwritten signature]*